Test Report

Report No.	20260710-HC-06061-15
Product Name	Bronze Gate Valve, DN15
Client	HOME CREATOR GROUP LTD

The Testing Centre of HOME CREATOR GROUP LTD

The Testing Centre of HOME CREATOR GROUP LTD

Test Report

Report No.: 20260710-HC-06061-15

Sample Name	Bronze Gate Valve, DN15	**Size/Model**	DN15
Product Code	HC-06061A	**Client**	HOME CREATOR GROUP LTD
Batch No.	/	**Receiving Date**	2026.07.6
Order No.	/	**Test Date**	2026.07.6~2026.07.10
Samples Qty.	6 Pcs	**Test Location**	Test Centre
Temperature	24℃	**Humidity**	60%
Equip.Status	Good	**Sample(s) Status**	Good
Test Std.	According to BS5154 standards		
Test Item(s)	1. Shell test ； 2.Seat sealing test		
Test Equip.(No.)	1.Water valve pressure test machine		
Test conclusion	The testing samples are qualified, acc. to the BS5154 standards requirement. the details of testing result pls see Page 3. **Date Issue： July 10th , 2026**		
Remarks	/		

Approved by **Daniel Cooper** **Verified by** **Andrew Clarke** **Inspector** **Christopher Bell**

Test Report

Report No.: 20260710-HC-06061-15

No.	Test item(s)	Test specification	Sample No.	Test Results	Judgment
1	Shell test	Opend the valves, one end is closed, and water enters from the other end. keep for 5 minute under the 37.5 bars water pressure . there should be no leakage.	1	No damage, no leakage	PASS
			2	No damage, no leakage	PASS
			3	No damage, no leakage	PASS
			4	No damage, no leakage	PASS
			5	No damage, no leakage	PASS
			6	No damage, no leakage	PASS
2	Seat sealing test	Closed the valves , the water enters from one end, and keep for 5 minutes under the 27.5 bar water pressure,there should be no leakage, two directions	1	No damage, no leakage	PASS
			2	No damage, no leakage	PASS
			3	No damage, no leakage	PASS
			4	No damage, no leakage	PASS
			5	No damage, no leakage	PASS
			6	No damage, no leakage	PASS
The End					