INSPECTION TEST CERTIFICATE

EN 10204-3.1

Report No.	HC-260353-45.91201.10F
Product Name	DN100 Ductile Iron FLANGED Y STRAINER
Invoice No.	HCAB01-26

HOME CREATOR GROUP LTD

INSPECTION TEST CERTIFICATE

EN 10204-3.1

Report No.: HC-260353-45.91201.10F

Sample Name	Ductile Iron FLANGED Y STRAINER	**Size/Model**	DN100
Product Code	HC-91201	**Client**	/
Batch No.	HCAB01-26	**Order No.**	HCAB01-26
Order Qty.	10 Pcs	**Sample(s) Qty.**	2 Pcs
Receiving Date	2026.07.01	**Test Date**	2026.07.01-2026.07.02
Temperature	29℃	**Humidity**	62%
Equip.Status	Fine	**Sample(s) Status**	Fine
Test Location	Testing center and Workshop		
Test Std.	Inspection in accordance with EN 12266. In accordance with BS EN 1171:2002. Flange in accordance with BS EN 1092-2.		
Test Item(s)	1)Material Verification 2)Visual Inspection 3)Dimensional Inspection 4)Wras Certificate Material 5)Pressure Testing (Per EN 12266)		
Test conclusion	The samples are on the inspection standard EN 12266, all test items meet the standards,Comprehensive judgment is OK.See the inspection result details in Page 3&Page 4. **Date of Issue： July 2nd , 2026**		
Remarks	/		

Approved by **Daniel Cooper** **Verified by** **Andrew Clarke** **Inspector** **Christopher Bell**

INSPECTION TEST CERTIFICATE

EN 10204-3.1

Report No.: HC-260353-45.91201.10F

No.	Test item(s)	Test specification												Judgment
1	Material Verification	Size of Valve	Part Names	CHEMICAL ANALYSIS %							MECHANICAL TESTS			
				Standard	C	Si	Mn	P	S	Nodule %	Tensile '(MPa)	Yield '(MPa)	Elong. %	Hard. HB
					3.55~3.85	2.34~2.86	≤0.6	≤0.08	≤0.025	≥80	≥500	≥320	≥7	170-230	
		DN100 PN16	GGG50 / BODY	Result	3.75	2.69	0.35	0.034	0.010	82.50	512	332	8.2	191	OK
2	Visual Inspection	Checking of order specifications, visual inspection of the surface , marking and nameplate .												OK
3	Dimensional Inspection	Item No.		1	2	3	4	5	6		7		8	Judgment
		Standards Faceto Face : EN558-1 End Flange: 1092-2		DN100	Φ156±2	Φ180±2	Φ220±2	19±2	350±3		8-Φ19		Φ1.5	
		Checked		OK	153.65	180.02	222.18	20.10	350.30		19.50		Φ1.5	OK
		Checked		OK	153.60	180.10	222.00	20.08	350.36		19.48		Φ1.5	OK
4	Wras Certificate Material	1.WRAS paiting according to RAL 5005												OK
		2. WRAS approved NBR ,												OK
5	Pressure Testing (Per EN 12266)	Test					Pressure (bar)				TIME (s)			Judgment
		Shell test - Hydrostatic, water at room temp.					24				60			OK

INSPECTION TEST CERTIFICATE

EN 10204-3.1

Report No.: HC-260353-45.91201.10F

No.	Test photo













