Test Report

Report No.	20260710-HC-99011DR-15
Product Name	DZR Hose Bib, DN15
Client	HOME CREATOR GROUP LTD

The Testing Centre of HOME CREATOR GROUP LTD

The Testing Centre of HOME CREATOR GROUP LTD

Test Report

Report No.: 20260710-HC-99011DR-15

Sample Name	DZR Hose Bib, DN15	**Size/Model**	DN15
Product Code	HC-99011DR	**Client**	HOME CREATOR GROUP LTD
Batch No.	/	**Receiving Date**	2026.07.6
Order No.	/	**Test Date**	2026.07.6~2026.07.10
Samples Qty.	6 Pcs	**Test Location**	Test Centre
Temperature	24℃	**Humidity**	60%
Equip.Status	Good	**Sample(s) Status**	Good
Test Std.	According to V&G internal product standards requirement.		
Test Item(s)	Shell test		
Test Equip.(No.)	Water valve pressure test machine		
Test conclusion	The testing samples are qualified, according to the relevant product standards requirement. the details of testing result please the see Page 3. **Date Issue: July 10th , 2026**		
Remarks	/		

Approved by **Daniel Cooper** **Verified by** **Andrew Clarke** **Inspector** **Christopher Bell**

The Testing Centre of HOME CREATOR GROUP LTD

Test Report

Report No.: 20260710-HC-99011DR-15

No.	Test item(s)	Test specification	Sample No.	Test Results	Judgment
1	Shell test	With the product in the fully open position, block the water outlet and apply a test water pressure of 24 bar. Maintain the pressure for 10 minutes. The product shall remain sealed with no leakage.	1	No damage, no leakage	PASS
			2	No damage, no leakage	PASS
			3	No damage, no leakage	PASS
			4	No damage, no leakage	PASS
			5	No damage, no leakage	PASS
			6	No damage, no leakage	PASS
The End					